

This Product MasterSpec Section is licensed by ARCOM to Jomar Valve. ("Licensee").

**This Product MasterSpec Section modifies the original MasterSpec text, and does not include the full content of the original MasterSpec Section.**

Revisions made to the original MasterSpec text are made solely by the Licensee and are not endorsed by, or representative of the opinions of, ARCOM or The American Institute of Architects (AIA). Neither AIA nor ARCOM are liable in any way for such revisions or for the use of this Product MasterSpec Section by any end user. A qualified design professional should review and edit the document to suit project requirements.

For more information, contact Jomar Valve, 7243 Miller Dr., Warren, MI 48092; Phone: (800) 325-5690; Fax: (800) 628-4194; Website: [www.jomarvalve.com](http://www.jomarvalve.com); Email: [csr@jomar.com](mailto:csr@jomar.com).

For information about MasterSpec contact ARCOM at (800) 424-5080 or visit [www.MasterSpec.com](http://www.MasterSpec.com).

## SECTION 230523.12 - BALL VALVES FOR HVAC PIPING

### **TIPS:**

To view non-printing **Editor's Notes** that provide guidance for editing, click on Masterworks/Single-File Formatting/Toggle/Editor's Notes.

To read **detailed research, technical information about products and materials, and coordination checklists**, click on Masterworks/Supporting Information.

## PART 1 - GENERAL

### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.2 SUMMARY

- A. Section Includes:
  - 1. Brass ball valves.
  - 2. Bronze ball valves.
  - 3. Carbon steel ball valves.
  - 4. Stainless steel ball valves.
  - 5. Iron ball valves.

### 1.3 DEFINITIONS

- A. ANSI: American National Standards Institute.

- B. Buna-N: Nitrile copolymer of butadiene and acrylonitrile.
- C. CSA: Canadian Standards Association.
- D. CWP: Cold working pressure.
- E. DZR: Dezincification Resistant.
- F. EPDM: Ethylene propylene-diene monomer rubber.
- G. FM: Factory Mutual.
- H. LF: Lead Free (Brass).
- I. MSS: Manufacturer's Standardization Society.
- J. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- K. NSF: National Sanitation Foundation.
- L. Pb: Lead.
- M. PTFE: Polytetrafluoroethylene.
- N. RPTFE: Reinforced Polytetrafluoroethylene.
- O. TFM: Modified Polytetrafluoroethylene (Hostaflon).
- P. T.E.A.: Ternary Ecological Alloy.
- Q. UL: Underwriters Laboratory.
- R. WOG: Water, Oil, and Gas.
- S. WSP: Working steam pressure.

#### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.

#### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  1. Protect internal parts against rust and corrosion.
  2. Protect threads, flange faces, and weld ends.
  3. Set ball valves open to minimize exposure of functional surfaces.
- B. Use the following precautions during storage:

1. Maintain valve end protection.
  2. Store valves indoors and maintain at higher-than-ambient-dew-point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use operating handles or stems as lifting or rigging points.

## PART 2 - PRODUCTS

### 2.1 GENERAL REQUIREMENTS FOR VALVES

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
1. ASME B1.20.1 for threads for threaded-end valves.
  2. ASME B16.1 for flanges on iron valves.
  3. ASME B16.5 for flanges on steel valves.
  4. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
  5. ASME B16.18 for solder-joint connections.
  6. ASME B31.1 for power piping valves.
  7. ASME B31.9 for building services piping valves.
- C. Refer to HVAC valve schedule articles for applications of valves.
- D. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- E. Valve Sizes: Same as upstream piping unless otherwise indicated.
- F. Valve Actuator Types:
1. Gear Actuator: For quarter-turn valves [NPS 10 (DN 250)] <Insert size> and larger.
  2. Handlever: For quarter-turn valves smaller than [NPS 10 (DN 250)] <Insert size>.
- G. Valves in Insulated Piping:
1. Include 2-inch (50-mm) stem extensions.
  2. Extended operating handle of nonthermal-conductive material, and protective sleeves that allow operation of valves without breaking the vapor seals or disturbing insulation.
  3. Memory stops that are fully adjustable after insulation is applied.
- H. Valve Bypass and Drain Connections: MSS SP-45.

### 2.2 BRASS BALL VALVES

- A. One-Piece Brass Ball Valves:

1. Manufacturers: Subject to compliance with requirements, [**provide products by the following**] [**provide products by one of the following**] [**available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following**]:
2. Basis-of-Design Product: Subject to compliance with requirements, provide [**product indicated on Drawings**] **<Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
  - a. Kitz Corporation.
  - b. **<Insert manufacturer's name>**.
3. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: **400 psig (2760 kPa)**.
  - c. Body Design: One piece.
  - d. Body Material: Forged brass.
  - e. Ends: Threaded.
  - f. Seats: PTFE.
  - g. Stem: Brass.
  - h. Ball: Chrome-plated brass.
  - i. Port: Reduced.

B. Two-Piece Brass Ball Valves with Full Port and Brass Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; [**T-100C**] [**S-100C**] [**T-100NE**] [**S-100NE**] or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. HCI, Hydronic Components, Inc.
  - c. Red-White Valve Corporation.
  - d. **<Insert manufacturer's name>**.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: **150 psig (1035 kPa)**.
  - c. WOG Rating:
    - 1) **600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20)**.
    - 2) **500 psig (3447 kPa), NPS 1-2 (DN 25-50)**.
    - 3) **400 psig (2757 kPa), NPS 2 1/2 - 4 (DN 65-100)**.
  - d. Body Design: Two piece.
  - e. Body Material: Forged brass.
  - f. Ends: Threaded and soldered.
  - g. Seats: TFM or PTFE.
  - h. Stem: Brass.
  - i. Ball: T.E.A. coated or chrome-plated brass.
  - j. Port: Full.

## C. Two-Piece Brass Ball Valves with Full Port and Stainless-Steel Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; [T-100SSE] [S-100SSE] [JF-100TG] [JF-100SG] or comparable product by one of the following:
  - a. Conbraco Industries, Inc., Apollo Valves.
  - b. HCI, Hydronic Components, Inc.
  - c. Kitz Corporation.
  - d. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: 150 psig (1035 kPa).
  - c. WOG Rating:
    - 1) 600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20).
    - 2) 500 psig (3447 kPa), NPS 1-2 (DN 25-50).
    - 3) 400 psig (2757 kPa), NPS 2 1/2 - 4 (DN 65-100).
  - d. Body Design: Two piece.
  - e. Body Material: Forged brass.
  - f. Ends: Threaded and soldered.
  - g. Seats: TFM or PTFE.
  - h. Stem: Stainless steel.
  - i. Ball: Stainless steel.
  - j. Port: Full.

## D. Two-Piece Brass Ball Valves with Full Port and Stainless-Steel Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; T-100SSS or comparable product by one of the following:
  - a. Conbraco Industries, Inc., Apollo Valves.
  - b. HCI, Hydronic Components, Inc.
  - c. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: 250 psig (1724 kPa).
  - c. WOG Rating:
    - 1) 600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20).
    - 2) 500 psig (3447 kPa), NPS 1-2 (DN 25-50).
  - d. Body Design: Two piece.
  - e. Body Material: Forged brass.
  - f. Ends: Threaded.
  - g. Seats: PTFE carbon graphite.

- h. Stem: Stainless steel.
- i. Ball: Stainless steel.
- j. Port: Full.

E. Two-Piece Brass Ball Valves with Regular Port and Brass Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; [T-100C] [S-100C] [T-100NE] [S-100NE] or comparable product by one of the following:
  - a. HCI, Hydronic Components, Inc.
  - b. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: 150 psig (1035 kPa).
  - c. WOG Rating:
    - 1) 600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20).
    - 2) 500 psig (3447 kPa), NPS 1-2 (DN 25-50).
    - 3) 400 psig (2757 kPa), NPS 2 1/2 - 4 (DN 65-100).
  - d. Body Design: Two piece.
  - e. Body Material: Forged brass.
  - f. Ends: Threaded and soldered.
  - g. Seats: TFM or PTFE.
  - h. Stem: Brass.
  - i. Ball: T.E.A. coated or chrome-plated brass.
  - j. Port: Regular.

F. Two-Piece Brass Ball Valves with Regular Port and Stainless-Steel Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; [T-100SSE] [S-100SSE] [JF-100TG] [JF-100SG] or comparable product by one of the following:
  - a. HCI, Hydronic Components, Inc.
  - b. Jamesbury; a subsidiary of Metso Automation.
  - c. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: 150 psig (1035 kPa).
  - c. WOG Rating:
    - 1) 600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20).
    - 2) 500 psig (3447 kPa), NPS 1-2 (DN 25-50).
    - 3) 400 psig (2757 kPa), NPS 2 1/2 - 4 (DN 65-100).

- d. Body Design: Two piece.
- e. Body Material: Forged brass.
- f. Ends: Threaded and soldered.
- g. Seats: TFM or PTFE.
- h. Stem: Stainless steel.
- i. Ball: Stainless steel.
- j. Port: Regular.

G. Three-Piece Brass Ball Valves with Full Port and Brass Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; **[T-600-4B]** **[S-600-4B]** or comparable product by one of the following:
  - a. Kitz Corporation.
  - b. Red-White Valve Corporation.
  - c. **<Insert manufacturer's name>**.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: **150 psig (1035 kPa)**.
  - c. WOG Rating: **600 psig (4140 kPa)**.
  - d. Body Design: Three piece.
  - e. Body Material: Forged brass.
  - f. Ends: Threaded and soldered.
  - g. Seats: RPTFE, PTFE.
  - h. Stem: Brass.
  - i. Ball: Chrome-plated brass.
  - j. Port: Full.

H. Three-Piece Brass Ball Valves with Full Port and Stainless-Steel Trim:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following]** **[provide products by one of the following]** **[available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings]** **<Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
  - a. Kitz Corporation.
  - b. Marwin Valve; a division of Richards Industries.
  - c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - d. **<Insert manufacturer's name>**.
3. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: **150 psig (1035 kPa)**.
  - c. WOG Rating: **600 psig (4140 kPa)**.
  - d. Body Design: Three piece.

- e. Body Material: Forged brass.
- f. Ends: Threaded.
- g. Seats: PTFE.
- h. Stem: Stainless steel.
- i. Ball: Stainless steel, vented.
- j. Port: Full.

## 2.3 BRONZE BALL VALVES

### A. One-Piece Bronze Ball Valves with Bronze Trim:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings] <Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. NIBCO INC.
  - c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - d. **<Insert manufacturer's name>**.
3. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: **400 psig (2760 kPa)**.
  - c. Body Design: One piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded.
  - f. Seats: PTFE.
  - g. Stem: Bronze.
  - h. Ball: Chrome-plated brass.
  - i. Port: Reduced.

### B. One-Piece Bronze Ball Valves with Stainless-Steel Trim:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings] <Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. NIBCO INC.
  - c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - d. **<Insert manufacturer's name>**.



3. Description:
  - a. Standard: MSS SP-110.
  - b. CWP Rating: 600 psig (4140 kPa).
  - c. Body Design: One piece.
  - d. Body Material: Bronze.
  - e. Ends: Threaded.
  - f. Seats: PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel, vented.
  - i. Port: Reduced.

C. Two-Piece Bronze Ball Valves with Full Port and Bronze or Brass Trim:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; T-100NEG or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. Red-White Valve Corporation.
  - c. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WSP Rating: 150 psig (1035 kPa).
  - c. WOG Rating:
    - 1) 600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20).
    - 2) 500 psig (3447 kPa), NPS 1-2 (DN 25-50).
  - d. Body Design: Two piece.
  - e. Body Material: Bronze or Dezincification Resistant Brass (CW511L).
  - f. Ends: Threaded.
  - g. Seats: TFM or PTFE.
  - h. Stem: Bronze or brass.
  - i. Ball: T.E.A. coated or chrome-plated brass.
  - j. Port: Full.

D. Two-Piece Bronze Ball Valves with Full Port and Stainless-Steel Trim:

1. Manufacturers: Subject to compliance with requirements, [provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:
2. Basis-of-Design Product: Subject to compliance with requirements, provide [product indicated on Drawings] <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. Crane Co.; Crane Valve Group; Crane Valves.
  - c. Hammond Valve.
  - d. Lance Valves; a division of Advanced Thermal Systems, Inc.

- e. Milwaukee Valve Company.
  - f. NIBCO INC.
  - g. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - h. <Insert manufacturer's name>.
3. Description:
- a. Standard: MSS SP-110.
  - b. WSP Rating: 150 psig (1035 kPa).
  - c. WOG Rating: 600 psig (4140 kPa).
  - d. Body Design: Two piece.
  - e. Body Material: Bronze.
  - f. Ends: Threaded.
  - g. Seats: PTFE.
  - h. Stem: Stainless steel.
  - i. Ball: Stainless steel, vented.
  - j. Port: Full.
- E. Two-Piece Bronze Ball Valves with Regular Port and Bronze or Brass Trim:
1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; T-100NEG or comparable product by one of the following:
    - a. Crane Co.; Crane Valves Group; Stockham Valves.
    - b. Hammond Valve.
    - c. <Insert manufacturer's name>.
  2. Description:
    - a. Standard: MSS SP-110.
    - b. WSP Rating: 150 psig (1035 kPa).
    - c. WOG Rating:
      - 1) 600 psig (4140 kPa), NPS 1/4-3/4 (DN 8-20).
      - 2) 500 psig (3447 kPa), NPS 1-2 (DN 25-50).
      - 3) 400 psig (2757 kPa), NPS 2 1/2 - 4 (DN 65-100).
    - d. Body Design: Two piece.
    - e. Body Material: Bronze or Dezincification Resistant Brass (CW511L).
    - f. Ends: Threaded.
    - g. Seats: TFM or PTFE.
    - h. Stem: Bronze or brass.
    - i. Ball: T.E.A. coated or chrome-plated brass.
    - j. Port: Regular.
- F. Two-Piece Bronze Ball Valves with Regular Port and Stainless-Steel Trim:
1. Manufacturers: Subject to compliance with requirements, [provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:

2. Basis-of-Design Product: Subject to compliance with requirements, provide [**product indicated on Drawings**] <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
  - a. Conbraco Industries; Apollo Valves.
  - b. Crane Co.; Crane Valves Group; Jenkins Valves.
  - c. Hammond Valve.
  - d. Milwaukee Valve Company.
  - e. NIBCO INC.
  - f. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - g. <Insert manufacturer's name>.
  
3. Description:
  - a. Standard: MSS SP-110.
  - b. SWP Rating: 150 psig (1035 kPa).
  - c. CWP Rating: 600 psig (4140 kPa).
  - d. Body Design: Two piece.
  - e. Body Material: Bronze.
  - f. Ends: Threaded.
  - g. Seats: PTFE.
  - h. Stem: Stainless steel.
  - i. Ball: Stainless steel, vented.
  - j. Port: Regular.

G. Three-Piece Bronze Ball Valves with Full Port and Bronze or Brass Trim:

1. Manufacturers: Subject to compliance with requirements, [**provide products by the following**] [**provide products by one of the following**] [**available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following**]:
2. Basis-of-Design Product: Subject to compliance with requirements, provide [**product indicated on Drawings**] <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. DynaQuip Controls.
  - c. Hammond Valve.
  - d. Milwaukee Valve Company.
  - e. NIBCO INC.
  - f. Red-White Valve Corporation.
  - g. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - h. <Insert manufacturer's name>.
  
3. Description:
  - a. Standard: MSS SP-110.
  - b. SWP Rating: 150 psig (1035 kPa).
  - c. CWP Rating: 600 psig (4140 kPa).
  - d. Body Design: Three piece.
  - e. Body Material: Bronze.

- f. Ends: Threaded.
- g. Seats: PTFE.
- h. Stem: Bronze.
- i. Ball: Chrome-plated brass.
- j. Port: Full.

H. Three-Piece Bronze Ball Valves with Full Port Stainless-Steel Trim:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings]** <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. Hammond Valve.
  - c. Milwaukee Valve Company.
  - d. NIBCO INC.
  - e. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - f. <Insert manufacturer's name>.
3. Description:
  - a. Standard: MSS SP-110.
  - b. SWP Rating: 150 psig (1035 kPa).
  - c. CWP Rating: 600 psig (4140 kPa).
  - d. Body Design: Three piece.
  - e. Body Material: Bronze.
  - f. Ends: Threaded.
  - g. Seats: PTFE.
  - h. Stem: Stainless steel.
  - i. Ball: Stainless steel, vented.
  - j. Port: Full.

I. Three-Piece Bronze Ball Valves with Regular Port, and Stainless-Steel Trim:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings]** <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. Jamesbury; a subsidiary of Metso Automation.
  - c. NIBCO INC.
  - d. <Insert manufacturer's name>.

3. Description:
  - a. Standard: MSS SP-110.
  - b. SWP Rating: 150 psig (1035 kPa).
  - c. CWP Rating: 600 psig (4140 kPa).
  - d. Body Design: Three piece.
  - e. Body Material: Bronze.
  - f. Ends: Threaded and solder.
  - g. Seats: PTFE.
  - h. Stem: Stainless steel.
  - i. Ball: Stainless steel, vented.
  - j. Port: Regular.

## 2.4 CARBON STEEL BALL VALVES

### A. Flanged, Class 150, Carbon Steel Ball Valves with Full Port:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; FL-CS-100-150 or comparable product by one of the following:
  - a. Conbraco Industries, Inc.; Apollo Valves.
  - b. Jamesbury; a subsidiary of Metso Automation.
  - c. NIBCO INC.
  - d. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-72.
  - b. WOG Rating: 285 psig (1964 kPa).
  - c. Body Design: Split body.
  - d. Body Material: Carbon steel, ASTM A 216, Type WCB.
  - e. Ends: Flanged.
  - f. Seats: PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel, vented.
  - i. Port: Full.

### B. Flanged, Class 300, Carbon Steel Ball Valves with Full Port:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; FL-CS-100-300 or comparable product by one of the following:
  - a. <Insert manufacturer's name>.
2. Description:
  - a. Standard: MSS SP-72.
  - b. WOG Rating: 720 psig (4960 kPa).
  - c. Body Design: Split body.
  - d. Body Material: Carbon steel, ASTM A 216, Type WCB.

- e. Ends: Flanged.
- f. Seats: PTFE.
- g. Stem: Stainless steel.
- h. Ball: Stainless steel, vented.
- i. Port: Full.

C. Two Piece, Carbon Steel Ball Valves with Full Port:

- 1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; T-CS-1001N-SS or comparable product by one of the following:
  - a. **<Insert manufacturer's name>**.
- 2. Description:
  - a. Standard: MSS SP-110.
  - b. WOG Rating: 1000 psig (6895 kPa).
  - c. Body Design: Two piece.
  - d. Body Material: Carbon steel, ASTM A 216, Type WCB.
  - e. Ends: Threaded.
  - f. Seats: TFM or PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel.
  - i. Port: Full.

D. Three Piece, Carbon Steel Ball Valves with Full Port:

- 1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; [T-CS-1000N-SS-4B] [S-CS-1000N-SS-4B] or comparable product by one of the following:
  - a. **<Insert manufacturer's name>**.
- 2. Description:
  - a. Standard: MSS SP-110.
  - b. WOG Rating: 1000 psig (6895 kPa).
  - c. Body Design: Three piece.
  - d. Body Material: Carbon steel, ASTM A 216, Type WCB.
  - e. Ends: Threaded or socket weld.
  - f. Seats: TFM or PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel.
  - i. Port: Full.

## 2.5 STAINLESS STEEL BALL VALVES

A. Flanged, Class 150, Stainless Steel Ball Valves with Full Port:

## PRODUCT MASTERSPEC LICENSED BY ARCOM TO JOMAR VALVE.

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; [FL-SS-100-150] [A2020D] or comparable product by one of the following:
    - a. <Insert manufacturer's name>.
  2. Description:
    - a. Standard: MSS SP-72.
    - b. WOG Rating: 285 psig (1964 kPa).
    - c. Body Design: Split body.
    - d. Body Material: Stainless steel, ASTM A 351, Type CF8M.
    - e. Ends: Flanged.
    - f. Seats: PTFE.
    - g. Stem: Stainless steel.
    - h. Ball: Stainless steel, vented.
    - i. Port: Full.
- B. Flanged, Class 300, Stainless Steel Ball Valves with Full Port:
1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; FL-SS-100-300 or comparable product by one of the following:
    - a. <Insert manufacturer's name>.
  2. Description:
    - a. Standard: MSS SP-72.
    - b. WOG Rating: 720 psig (4960 kPa).
    - c. Body Design: Split body.
    - d. Body Material: Stainless steel, ASTM A 351, Type CF8M.
    - e. Ends: Flanged.
    - f. Seats: PTFE.
    - g. Stem: Stainless steel.
    - h. Ball: Stainless steel, vented.
    - i. Port: Full.
- C. Two Piece, Stainless Steel Ball Valves with Full Port:
1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; T-SS-1001N or comparable product by one of the following:
    - a. <Insert manufacturer's name>.
  2. Description:
    - a. Standard: MSS SP-110.
    - b. WOG Rating: 1000 psig (6895 kPa).
    - c. Body Design: Two piece.
    - d. Body Material: Stainless steel, ASTM A 351, Type CF8M.
    - e. Ends: Threaded.
    - f. Seats: TFM or PTFE.

- g. Stem: Stainless steel.
- h. Ball: Stainless steel.
- i. Port: Full.

D. Three Piece, Stainless Steel Ball Valves with Full Port:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; **[T-SS-1000N-4B] [S-SS-1000N-4B]** or comparable product by one of the following:
  - a. **<Insert manufacturer's name>**.
2. Description:
  - a. Standard: MSS SP-110.
  - b. WOG Rating: **1000 psig (6895 kPa)**.
  - c. Body Design: Three piece.
  - d. Body Material: Stainless steel, ASTM A 351, Type CF8M.
  - e. Ends: Threaded or socket weld.
  - f. Seats: TFM or PTFE.
  - g. Stem: Stainless steel.
  - h. Ball: Stainless steel.
  - i. Port: Full.

## 2.6 IRON BALL VALVES

A. Class 125 Iron Ball Valves:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings] <Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
  - a. American Valve, Inc.
  - b. Conbraco Industries; Apollo Valves.
  - c. Kitz Corporation.
  - d. Sure Flow Equipment Inc.
  - e. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - f. **<Insert manufacturer's name>**.
3. Description:
  - a. Standard: MSS SP-72.
  - b. CWP Rating: **200 psig (1380 kPa)**.
  - c. Body Design: Split body.
  - d. Body Material: ASTM A 126, gray iron.
  - e. Ends: Flanged.
  - f. Seats: PTFE.



- g. Stem: Stainless steel.
- h. Ball: Stainless steel.
- i. Port: Full.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

#### 3.2 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install valve tags. Comply with requirements in Section 230553 "Identification for HVAC Piping and Equipment" for valve tags and schedules.

#### 3.3 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS

- A. If valves with specified WSP classes or WOG ratings are unavailable, the same types of valves with higher WSP classes or WOG ratings may be substituted.
- B. Select valves with the following end connections:
  - 1. For Copper Tubing, **NPS 2 (DN 50)** and Smaller: Threaded ends except where solder-joint valve-end option is indicated in valve schedules below.
  - 2. For Copper Tubing, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: Threaded ends except where flanged or solder valve-end option is indicated in valve schedules below.

3. For Copper Tubing, **NPS 5 (DN 125)** and Larger: Flanged ends.
4. For Steel Piping, **NPS 2 (DN 50)** and Smaller: Threaded ends except where solder-joint valve-end option is indicated in the valve schedules below.
5. For Steel Piping, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: Flanged ends except where threaded or solder valve-end option is indicated in valve schedules below.
6. For Steel Piping, **NPS 5 (DN 125)** and Larger: Flanged ends.

### 3.4 CHILLED-WATER VALVE SCHEDULE

- A. Pipe **NPS 2 (DN 50)** and Smaller: [**Two**] [**Three**] piece, full port, brass with brass or stainless-steel trim.
  1. Valves may be provided with solder-joint ends instead of threaded ends.
- B. Pipe **NPS 2-1/2 (DN 65)** and Larger: Iron ball valves.
  1. Iron Valves, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: May be provided with threaded ends instead of flanged ends.
  2. Steel Ball Valves: Class 150.
- C. Pipe **NPS 2-1/2 (DN 65)** and Larger:
  1. Iron ball valves.
    - a. Iron Valves, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: May be provided with threaded ends instead of flanged ends.
  2. Class 150 steel ball valves.

### 3.5 CONDENSER-WATER VALVE SCHEDULE

- A. Pipe **NPS 2 (DN 50)** and Smaller: [**One**] [**Two**] [**Three**] piece, [**full**] [**regular**] [**reduced**] port, [**brass**] [**or**] [**bronze**] with [**brass**] [**bronze**] [**stainless-steel**] trim.
  1. Valves may be provided with solder-joint ends instead of threaded ends.
- B. Pipe **NPS 2-1/2 (DN 65)** and Larger:
  1. Iron ball valves.
    - a. Iron Valves, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: May be provided with threaded ends instead of flanged ends.
  2. Class 150 steel ball valves.

### 3.6 HEATING-WATER VALVE SCHEDULE

- A. Pipe **NPS 2 (DN 50)** and Smaller: [**One**] [**Two**] [**Three**] piece, [**full**] [**regular**] [**reduced**] port, [**brass**] [**or**] [**bronze**] with [**brass**] [**bronze**] [**stainless-steel**] trim.

1. Valves may be provided with solder-joint ends instead of threaded ends.
- B. Pipe **NPS 2-1/2 (DN 65)** and Larger:
1. Iron ball valves.
    - a. Iron Valves, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: May be provided with threaded ends instead of flanged ends.
  2. Class 150 steel ball valves.
- 3.7 LOW-PRESSURE STEAM VALVE SCHEDULE (**15 PSIG ([104 kPa])** OR LESS)
- A. Pipe **NPS 2 (DN 50)** and Smaller: **[One] [Two] [Three]** piece, **[full] [regular] [reduced]** port, **[brass] [or] [bronze]** with **[brass] [bronze] [stainless-steel]** trim.
- B. Pipe **NPS 2-1/2 (DN 65)** and Larger:
1. Iron ball valves.
    - a. Iron Valves, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: May be provided with threaded ends instead of flanged ends.
  2. Class 150 steel ball valves.
- 3.8 HIGH-PRESSURE STEAM VALVE SCHEDULE (MORE THAN **15 PSIG ([104 kPa])**)
- A. Pipe **NPS 2 (DN 50)** and Smaller: **[One] [Two] [Three]** piece, **[full] [regular] [reduced]** port, **[brass] [or] [bronze]** with **[brass] [bronze] [stainless-steel]** trim.
- B. Pipe **NPS 2-1/2 (DN 65)** and Larger:
1. Iron ball valves.
    - a. Iron Valves, **NPS 2-1/2 to NPS 4 (DN 65 to DN 100)**: May be provided with threaded ends instead of flanged ends.
  2. Class 300 steel ball valves.
- 3.9 STEAM-CONDENSATE VALVE SCHEDULE
- A. Pipe **NPS 2 (DN 50)** and Smaller: **[One] [Two] [Three]** piece, **[full] [regular] [reduced]** port, **[brass] [or] [bronze]** with **[brass] [bronze] [stainless-steel]** trim.
- B. Pipe **NPS 2-1/2 (DN 65)** and Larger:
1. Iron ball valves.

PRODUCT MASTERSPEC LICENSED BY ARCOM TO JOMAR VALVE.

- a. Iron Valves, **NPS 2-1/2 to NPS 4** (DN 65 to DN 100): May be provided with threaded ends instead of flanged ends.
2. Class 300 steel ball valves.

END OF SECTION 230523.12