

This Product MasterSpec Section is licensed by ARCOM to Jomar Valve ("Licensee").

This Product MasterSpec Section modifies the original MasterSpec text, and does not include the full content of the original MasterSpec Section.

Revisions made to the original MasterSpec text are made solely by the Licensee and are not endorsed by, or representative of the opinions of, ARCOM or The American Institute of Architects (AIA). Neither AIA nor ARCOM are liable in any way for such revisions or for the use of this Product MasterSpec Section by any end user. A qualified design professional should review and edit the document to suit project requirements.

For more information, contact Jomar Valve, 7243 Miller Dr., Warren, MI 48092; Phone: (800) 325-5690; Fax: (800) 628-4194; Website: www.jomarvalve.com; Email: csr@jomar.com.

For information about MasterSpec contact ARCOM at (800) 424-5080 or visit www.MasterSpec.com.

SECTION 230523.13 - BUTTERFLY VALVES FOR HVAC PIPING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Iron, single-flange butterfly valves.
 - 2. Iron, grooved-end butterfly valves.
 - 3. High-performance butterfly valves.
 - 4. Chainwheels.

1.3 DEFINITIONS

- A. ANSI: American National Standards Institute.
- B. Buna-N: Nitrile copolymer of butadiene and acrylonite.
- C. CSA: Canadian Standards Association.
- D. CWP: Cold working pressure.
- E. EPDM: Ethylene propylene copolymer rubber.

BUTTERFLY VALVES FOR HVAC PIPING

- F. MSS: Manufacturer's Standardization Society.
- G. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- H. SWP: Steam working pressure.
- I. NSF: National Sanitation Foundation.
- J. Pb: Lead
- K. PTFE: Polytetrafluoroethylene.
- L. RPTFE: Reinforced Polytetrafluoroethylene.
- M. UL: Underwriters Laboratory.
- N. Viton: Fluoropolymer Elastomer.
- O. WOG: Water, Oil, and Gas.
- P. WSP: Working Steam Pressure.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of valve.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
 - 1. Protect internal parts against rust and corrosion.
 - 2. Protect threads, flange faces, grooves, and weld ends.
 - 3. Set butterfly valves closed or slightly open.
- B. Use the following precautions during storage:
 - 1. Maintain valve end protection.
 - 2. Store valves indoors and maintain at higher-than-ambient-dew-point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

PART 2 - PRODUCTS

2.1 GENERAL REQUIREMENTS FOR VALVES

BUTTERFLY VALVES FOR HVAC PIPING

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
 - 1. ASME B16.1 for flanges on iron valves.
 - 2. ASME B16.5 for pipe flanges and flanged fittings, NPS 1/2 through NPS 24.
 - 3. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
 - 4. ASME B31.1 for power piping valves.
 - 5. ASME B31.9 for building services piping valves.
- C. AWWA Compliance: Comply with AWWA C606 for grooved-end connections.
- D. Valve Pressure-Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
- E. Valve Sizes: Same as upstream piping unless otherwise indicated.
- F. Valve Actuator Types:
 - 1. Gear Actuator: For valves **NPS 8 (DN 200)** and larger.
 - 2. Handlever: For valves **NPS 6 (DN 150)** and smaller.
 - 3. Chainwheel: Device for attachment to gear, stem, or other actuator of size and with chain for mounting height, according to "Valve Installation" Article.
- G. Valves in Insulated Piping: With **2-inch (50-mm)** stem extensions with extended necks.

2.2 IRON, SINGLE-FLANGE BUTTERFLY VALVES

- A. Iron, Single-Flange Butterfly Valves with Aluminum-Bronze Disc:
 - 1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
 - 2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings] <Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
 - a. ABZ Valve and Controls; a division of ABZ Manufacturing, Inc.
 - b. Bray Controls; a division of Bray International.
 - c. Cooper Cameron Valves; a division of Cooper Cameron Corporation.
 - d. Conbraco Industries, Inc.; Apollo Valves.
 - e. Crane Co.; Crane Valve Group; Jenkins Valves.
 - f. Crane Co.; Crane Valve group; Stockham Valves.
 - g. DeZurik Water Controls.
 - h. Hammond Valve.
 - i. Kitz Corporation.
 - j. Milwaukee Valve Company.
 - k. NIBCO INC.

PRODUCT MASTERSPEC LICENSED BY ARCOM TO JOMAR VALVE.

- l. Norriseal; a Dover Corporation company.
 - m. Red-White Valve Corporation.
 - n. Spence Engineering Company; a division of CICOR International, Inc.
 - o. Tyco Valves & Controls; a unit of Tyco Flow Control.
 - p. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
 - q. **<Insert manufacturer's name>**.
3. Description:
- a. Standard: MSS SP-67, Type I.
 - b. CWP Rating: [**150 psig (1035 kPa)**] [**200 psig (1380 kPa)**].
 - c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
 - d. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
 - e. Seat: [**EPDM**] [**NBR**].
 - f. Stem: One- or two-piece stainless steel.
 - g. Disc: Aluminum bronze.

B. Iron, Single-Flange Butterfly Valves with Ductile-Iron Disc:

1. Manufacturers: Subject to compliance with requirements, [**provide products by the following**] [**provide products by one of the following**] [**available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following**]:
2. Basis-of-Design Product: Subject to compliance with requirements, provide [**product indicated on Drawings**] **<Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
 - a. ABZ Valve and Controls; a division of ABZ Manufacturing, Inc.
 - b. Bray Controls; a division of Bray International.
 - c. Cooper Cameron Valves; a division of Cooper Cameron Corporation.
 - d. Conbraco Industries, Inc.; Apollo Valves.
 - e. Crane Co.; Crane Valve Group; Center Line Valves.
 - f. Crane Co.; Crane Valve Group; Stockham Valves.
 - g. DeZurik Water Controls.
 - h. Hammond Valve.
 - i. Kitz Corporation.
 - j. Milwaukee Valve Company.
 - k. Mueller Steam Specialty; a division of SPX Corporation.
 - l. NIBCO INC.
 - m. Norriseal; a Dover company.
 - n. Spence Engineering Company; a division of CICOR International, Inc.
 - o. Sure Flow Equipment Inc.
 - p. Tyco Valves & Controls; a unit of Tyco Flow Control.
 - q. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
 - r. **<Insert manufacturer's name>**.
3. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating: [**150 psig (1035 kPa)**] [**200 psig (1380 kPa)**].

- c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
- d. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
- e. Seat: **[EPDM]** **[NBR]**.
- f. Stem: One- or two-piece stainless steel.
- g. Disc: Nickel-plated **[or -coated]** ductile iron.

C. Iron, Single-Flange Butterfly Valves with Stainless-Steel Disc:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Jomar Valve; 600 Series BFV or comparable product by one of the following:
 - a. Conbraco Industries, Inc.; Apollo Valves.
 - b. Crane Co.; Crane Valve Group; Stockham Valves.
 - c. HCI, Hydronic Components, Inc.
 - d. Milwaukee Valve Company.
 - e. Red-White Valve Corporation.
 - f. **<Insert manufacturer's name>**.
2. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. CWP Rating:
 - 1) **NPS 1/2 (DN 15) to NPS 12 (DN 300): [100 psig (690 kPa) without downstream flange] [200 psig (1380 kPa) with downstream flange].**
 - 2) **NPS 14 (DN 350) to NPS 24 (DN 600): 150 psig (1035 kPa) with downstream flange.**
 - c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
 - d. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
 - e. Seat: **[EPDM]** **[NBR]** **[Viton]**.
 - f. Stem: One- or two-piece stainless steel.
 - g. Disc: Stainless steel.

2.3 DUCTILE-IRON, GROOVED-END BUTTERFLY VALVES

A. 175 CWP, Iron, Grooved-End Butterfly Valves:

1. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
2. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings]** **<Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
 - a. Kennedy Valve; a division of McWane, Inc.
 - b. Shurjoint Piping Products.
 - c. Tyco Fire Products LP; Grinnell Mechanical Products.

- d. Victaulic Company.
 - e. <Insert manufacturer's name>.
3. Description:
- a. Standard: MSS SP-67, Type I.
 - b. CWP Rating: 175 psig (1200 kPa).
 - c. Body Material: Coated, ductile iron.
 - d. Stem: Two-piece stainless steel.
 - e. Disc: Coated, ductile iron.
 - f. Seal: EPDM.

B. 300 CWP, Iron, Grooved-End Butterfly Valves:

- 1. Manufacturers: Subject to compliance with requirements, [provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:
- 2. Basis-of-Design Product: Subject to compliance with requirements, provide [product indicated on Drawings] <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
 - a. Anvil International, Inc.
 - b. Kennedy Valve Company; a division of McWane, Inc.
 - c. Mueller Steam Specialty; a division of SPX Corporation.
 - d. NIBCO INC.
 - e. Shurjoint Piping Products.
 - f. Tyco Fire Products LP; Grinnell Mechanical Products.
 - g. Victaulic Company.
 - h. <Insert manufacturer's name>.
- 3. Description:
 - a. Standard: MSS SP-67, Type I.
 - b. NPS 8 (DN 50) and Smaller CWP Rating: 300 psig (2070 kPa).
 - c. NPS 10 (DN 250) and Larger CWP Rating: 200 psig (1380 kPa).
 - d. Body Material: Coated, ductile iron.
 - e. Stem: Two-piece stainless steel.
 - f. Disc: Coated, ductile iron.
 - g. Seal: EPDM.

2.4 HIGH-PERFORMANCE BUTTERFLY VALVES

A. Class 150, Single-Flange, High-Performance Butterfly Valves:

- 1. Manufacturers: Subject to compliance with requirements, [provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:

2. Basis-of-Design Product: Subject to compliance with requirements, provide [**product indicated on Drawings**] <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
 - a. ABZ Valve and Controls; a division of ABZ Manufacturing, Inc.
 - b. Bray Controls; a division of Bray International.
 - c. Cooper Cameron Valves; a division of Cooper Cameron Corporation.
 - d. Crane Co.; Crane Valve Group; Flowseal Brand.
 - e. Crane Co.; Crane Valve Group; Stockham Valves.
 - f. DeZurik Water Controls.
 - g. Hammond Valve.
 - h. Jamesbury; a subsidiary of Metso Automation.
 - i. Milwaukee Valve Company.
 - j. NIBCO INC.
 - k. Process Development & Control, Inc.
 - l. Tyco Valves & Controls; a unit of Tyco Flow Control.
 - m. Xomox; a brand of Crane Co.
 - n. <Insert manufacturer's name>.

3. Description:

- a. Standard: MSS SP-68.
- b. CWP Rating: 285 psig (1965 kPa) at 100 deg F (38 deg C).
- c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
- d. Body Material: Carbon steel, cast iron, ductile iron, or stainless steel.
- e. Seat: Reinforced PTFE or metal.
- f. Stem: Stainless steel; offset from seat plane.
- g. Disc: Carbon steel.
- h. Service: Bidirectional.

- B. Class 300, Single-Flange, High-Performance Butterfly Valves:

1. Manufacturers: Subject to compliance with requirements, [**provide products by the following**] [**provide products by one of the following**] [**available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following**]:
2. Basis-of-Design Product: Subject to compliance with requirements, provide [**product indicated on Drawings**] <Insert manufacturer's name; product name or designation> or comparable product by one of the following:
 - a. ABZ Valve and Controls; a division of ABZ Manufacturing, Inc.
 - b. Bray Controls; a division of Bray International.
 - c. Cooper Cameron Valves; a division of Cooper Cameron Corporation.
 - d. Crane Co.; Crane Valve Group; Flowseal Valves.
 - e. Crane Co.; Crane Valve Group; Stockham Valves.
 - f. DeZurik Water Controls.
 - g. Hammond Valve.
 - h. Jamesbury; a subsidiary of Metso Automation.
 - i. Milwaukee Valve Company.
 - j. NIBCO INC.

- k. Process Development & Control, Inc.
 - l. Tyco Valves & Controls; a unit of Tyco Flow Control.
 - m. Xomox; a brand of Crane Co.
 - n. <Insert manufacturer's name>.
3. Description:
- a. Standard: MSS SP-68.
 - b. CWP Rating: 720 psig (4965 kPa) at 100 deg F (38 deg C).
 - c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
 - d. Body Material: Carbon steel, cast iron, or ductile iron.
 - e. Seat: Reinforced PTFE or metal.
 - f. Stem: Stainless steel; offset from seat plane.
 - g. Disc: Carbon steel.
 - h. Service: Bidirectional.

2.5 CHAINWHEELS

- A. Manufacturers: Subject to compliance with requirements, **[provide products by the following] [provide products by one of the following] [available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following]:**
- B. Basis-of-Design Product: Subject to compliance with requirements, provide **[product indicated on Drawings] <Insert manufacturer's name; product name or designation>** or comparable product by one of the following:
1. Babbitt Steam Specialty Co.
 2. Roto Hammer Industries.
 3. Trumbull Industries.
 4. <Insert manufacturer's name>.
- C. Description: Valve actuation assembly with sprocket rim, chain guides, chain[, **and attachment brackets for mounting chainwheels directly to hand wheels**].
1. Sprocket Rim with Chain Guides: **[Ductile iron] [Ductile or cast iron] [Cast iron] [Aluminum] [Bronze]**, of type and size required for valve. **[Include zinc or epoxy coating.]**
 2. Chain: **[Hot-dip, galvanized steel] [Brass] [Stainless steel]**, of size required to fit sprocket rim.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.

- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine mating flange faces for damage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- D. Do not attempt to repair defective valves; replace with new valves.

3.2 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install chainwheels on operators for butterfly valves **[NPS 4 (DN 100)]** <Insert size> and larger and more than **[96 inches (2400 mm)]** <Insert dimension> above floor. Extend chains to **[60 inches (1520 mm)]** <Insert dimension> above finished floor.
- F. Install valve tags. Comply with requirements in Section 230553 "Identification for HVAC Piping and Equipment" for valve tags and schedules.

3.3 ADJUSTING

- A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

3.4 CHILLED-WATER VALVE SCHEDULE

- A. Pipe **NPS 2-1/2 (DN 65)** and Larger:
 - 1. Iron, Single-Flange Butterfly Valves, **NPS 2-1/2 to NPS 12 (DN 65 to DN 300)**: 200 CWP, **[EPDM]** **[NBR]** seat, **[aluminum-bronze]** **[ductile-iron]** **[stainless-steel]** disc.
 - 2. Iron, Single-Flange Butterfly Valves, **NPS 14 to NPS 24 (DN 350 to DN 600)**: 150 CWP, **[EPDM]** **[NBR]** seat, **[aluminum-bronze]** **[ductile-iron]** **[stainless-steel]** disc.
 - 3. Iron, Grooved-End Butterfly Valves, **NPS 2-1/2 to NPS 12 (DN 65 to DN 300)**: **[175]** **[300]** CWP.
 - 4. High-Performance Butterfly Valves: **[Class 150]** **[Class 300]**, single flange.

3.5 CONDENSER-WATER VALVE SCHEDULE

A. Pipe **NPS 2-1/2 (DN 65)** and Larger:

1. Iron, Single-Flange Butterfly Valves, **NPS 2-1/2 to NPS 12 (DN 65 to DN 300)**: 200 CWP, **[EPDM]** **[NBR]** seat, **[aluminum-bronze]** **[ductile-iron]** **[stainless-steel]** disc.
2. Iron, Single-Flange Butterfly Valves, **NPS 14 to NPS 24 (DN 350 to DN 600)**: 150 CWP, **[EPDM]** **[NBR]** seat, **[aluminum-bronze]** **[ductile-iron]** **[stainless-steel]** disc.
3. Iron, Grooved-End Butterfly Valves, **NPS 2-1/2 to NPS 12 (DN 65 to DN 300)**: **[175]** **[300]** CWP.
4. High-Performance Butterfly Valves: **[Class 150]** **[Class 300]**, single flange.

3.6 HEATING-WATER VALVE SCHEDULE

A. Pipe **NPS 2-1/2 (DN 65)** and Larger:

1. Iron, Single-Flange Butterfly Valves, **NPS 2-1/2 to NPS 12 (DN 65 to DN 300)**: 200 CWP, **[EPDM]** **[NBR]** seat, **[aluminum-bronze]** **[ductile-iron]** **[stainless-steel]** disc.
2. Iron, Single-Flange Butterfly Valves, **NPS 14 to NPS 24 (DN 350 to DN 600)**: 150 CWP, **[EPDM]** **[NBR]** seat, **[aluminum-bronze]** **[ductile-iron]** **[stainless-steel]** disc.
3. Iron, Grooved-End Butterfly Valves, **NPS 2-1/2 to NPS 12 (DN 65 to DN 300)**: **[175]** **[300]** CWP.
4. High-Performance Butterfly Valves: **[Class 150]** **[Class 300]**, single flange.

3.7 LOW-PRESSURE STEAM VALVE SCHEDULE (**15 PSIG ([104 kPa])** OR LESS)

- A. Pipe
- NPS 2-1/2 (DN 65)**
- and Larger:
- [Class 150]**
- [Class 300]**
- , high-performance butterfly valves, single flange.

3.8 HIGH-PRESSURE STEAM VALVE SCHEDULE (MORE THAN **15 PSIG ([104 kPa])**)

- A. Pipe
- NPS 2-1/2 (DN 65)**
- and Larger:
- [Class 150]**
- [Class 300]**
- , high-performance butterfly valves, single flange.

3.9 STEAM-CONDENSATE VALVE SCHEDULE

- A. Pipe
- NPS 2-1/2 (DN 65)**
- and Larger:
- [Class 150]**
- [Class 300]**
- , high-performance butterfly valves, single flange.

END OF SECTION 230523.13